



Purchasing Division

ADDENDUM NO. 2

DATE: January 20, 2026
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Safe Routes to School – Ella Street IFB-5768-26-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

- 1. Question:** Can the tree trimming be done by a non-certified tree arborist?
Answer: A certified arborist is required to perform the tree trimming.
- 2. Question:** Can the asphalt patching be done by hand or will a paver be required?
Answer: Asphalt patching may be performed by hand, but a roller and compaction testing will be required.
- 3. Question:** Will a street closure with detours be allowed or will the road need to be open with flaggers preferred?
Answer: A single lane closure is permitted. However, local traffic in both directions shall be maintained with flaggers utilized as needed.
- 4. Question:** Bid Item 19 on the Bid Schedule seems to be missing a quantity and the lines to place our numbers?
Answer: An updated Bid Schedule is being attached to this Addendum. Please use this revised Bid Schedule when submitting your bid.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that appears to read "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado

Bid Schedule: SRTS - Ella Street Addendum No. 2

Item No.	CDOT, City Ref.	Description	Quantity	Units	Unit	Price	Total Price
1	201	Clearing and Grubbing		Lump Sum	---	\$ _____	
2	202	Tree Trimming (216 Lilac Lane)		Lump sum	---	\$ _____	
3	202	Remove Existing Concrete (Includes Curb & Gutter, Sidewalk & Pavement)	14.	SY	\$ _____	\$ _____	
4	202	Remove Asphalt Mat (Full Depth)	101.	SY	\$ _____	\$ _____	
5	202	Remove Asphalt Mat (Planing) (2" Depth)	46.	SY	\$ _____	\$ _____	
6	203	Unclassified Excavation	36.	CY	\$ _____	\$ _____	
7	203	Embankement Material	20.	CY	\$ _____	\$ _____	
8	203	Muck Excavation (Subgrade Stabilization as directed by Project Engineer)	20.	CY	\$ _____	\$ _____	
9	207	Topsoil (4" Depth)	10.	CY	\$ _____	\$ _____	
10	208	Erosion Control (Complete in Place)		Lump Sum	---	\$ _____	
11	208	Concrete Washout Facility	1.	EA	\$ _____	\$ _____	
12	304	Class 3 Aggregate Base Course (Subgrade Stablilization as directed by Project	18.	TON	\$ _____	\$ _____	
13	304	Aggregate Base Course (Class 6)	71.	TON	\$ _____	\$ _____	
14	306	Reconditioning (6" Depth)	182.	SY	\$ _____	\$ _____	
15	401	Hot Mix Asphalt (5" Thick) (Grading SX, 75 Binder Grade, PG 64-22) (One (1) - 3" Lift & Two (2) - 1 1/2" Lifts)		13.05 Ton	\$ _____	\$ _____	
16	401	Hot Mix Asphalt (2" & Variable Thickness) (Grading SX, 75 Binder Grade, PG 64-22) (One (1) - 2" Lift)	5.04	Ton	\$ _____	\$ _____	
17	420	Geotextile Separator (CI 2) (Subgrade Stabilization as directed by Project	56.47	SY	\$ _____	\$ _____	
18	608	Monolithic Drive Over Concrete Curb, Gutter & Sidewalk (6") (City of Grand Junction Std. Detail C-03)	118.	SY	\$ _____	\$ _____	
19	608	Concrete Curb Ramp (Per CDOT M&S Std. Plan M-608-1, Sht. 5)	17.	SY	\$ _____	\$ _____	
20	608	Detectable Warnings (Per CDOT M&S Std. Plan M-608-1, Sht. 9)	2.	EA	\$ _____	\$ _____	
21	620	Sanitary Facility		Lump Sum	---	\$ _____	
22	625	Construction Surveying (Includes As-Built Drawings)		Lump Sum	---	\$ _____	
23	626	Mobilization		Lump Sum	---	\$ _____	
24	630	Traffic Control (Complete in Place)		Lump Sum	---	\$ _____	
MCR		Minor Contract Revisions		---	---	\$	3,500.00

Bid Amount: \$

Bid Amount: dollars