

THE TRANE COMPANY
A DIVISION OF AMERICAN STANDARD INC.
INTELLIPAK



MODEL NUMBER **SLHGD13463J8CGGD9001ABWE00000NRT0Y60#**

SERIAL NUMBER **C07E05006**

LISTED
AIR CONDITIONING
SYSTEM EQUIPMENT
SELF-CONTAINED UNIT
59R9

ATED VOLTAGE	460	HZ	60	PHASE	3
UTILIZATION VOLTAGE RANGE	414-506				
MINOMINAL SYSTEM VOLTAGES	440-460-480				
MINIMUM CIRCUIT AMPACITY	CIRCUIT-1		CIRCUIT-2	CIRCUIT-3	
RECOMMENDED DUAL ELEMENT FUSE	400			AMPS	
MAXIMUM OVERCURRENT PROTECTION DEVICE	400			AMPS	
	400			AMPS	

	QTY	VOLTS	HZ	PHASE	RLA EA	LRA EA
COMPRESSOR MOTOR A	2	460	60	3	27.3	178
COMPRESSOR MOTOR B	2	460	60	3	27.3	178
COMPRESSOR MOTOR C	2	460	60	3	27.3	178
COMPRESSOR MOTOR D	2	460	60	3	27.3	178

	QTY	VOLTS	HZ	PHASE	FLA EA	HP EA
CONDENSER FAN MOTOR	12	460	60	3	1.8	1.00
VAPORATOR FAN MOTOR	2	460	60	3	48.5	40.0
EXHAUST FAN MOTOR	1	460	60	3	48.5	40.0
BURNER MOTOR	-0-					-0-
ELECTRIC HEATER CKT	-0-				-0-	KW
VAPORATOR HEAT TAPE		-0-				VA
UNIT CONTROL CIRCUIT		460	60	1	2	VA

FACTORY CHARGED - EACH SYSTEM 120 CKT 1 120 CKT 2 LBS OF R-22
DESIGN PRESSURE 450 PSIG TEST PRESSURE 450 HIGH (PSIG) 300 LOW (PSIG)

FOR NONRESIDENTIAL INSTALLATION ONLY

THIS UNIT COMPLIES WITH THE
ENERGY EFFICIENCY RATINGS OF ASHRAE 90.1

MANUALS

RT-SVX10E-E

RT-SVP02A-E

UNIT	2308-4492-01	2308-2381-01	2309-3024-01	2307-4524-01
WIRING	2307-3892-01	2308-1028-01	2308-2399-01	2308-1530-01
DIAGRAMS	2308-2790-01			2309-3200-01
	2309-3201-01	2309-3202-01		