



Purchasing Division

ADDENDUM NO. 1

DATE: **February 12, 2026**
FROM: **City of Grand Junction Purchasing Division**
TO: **All Offerors**
RE: **Water Treatment Plant South Tank Recoating Project IFB-5836-26-DD**

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following questions/answers/clarifications:

1. Question: Will the City or Contractor provide an inspector?

Answer: The City will arrange a 3rd party inspector for the duration of the project. This inspector will be an AMPP Certified Coatings Inspector. This Addendum response replaces statements made in the previous bid documents explaining that the Contractor will pay for inspection costs.

2. Question: Will the City provide replacement bolts for the outlet nozzle replacement if the existing bolts are not reusable?

Answer: Yes

3. Question: During the tank interior walkthrough, a pinhole was observed in the roof. Will the City want the Contractor to repair this pinhole?

Answer: No

4. Question: In the Project Specifications document, the Stripe Coat thickness is listed as the same thickness as the final Coat. Is this a typo?

Answer: Yes, the Stripe Coat thickness is a typo and should be approximately 5-8 mils thickness.

5. Question: Since product curing is temperature and weather dependent, will the Contractor be allowed to work extended hours, for example 7am to 7pm?

Answer: Yes, due to cold weather concerns extended hours are allowed upon approval from the City Engineer.

6. Question: Which blast profile is required?

Answer: Prepare all coated surfaces to SSPC-SP 10 / NACE No. 2, Near-White Metal Blast Cleaning with a minimum angular surface profile of 1.5 to 2.5 mils.

7. Question: Will the City approve OBIC 1000 Multilayer Liner System product for use on this project?

Answer: No

*****Engineering Design Document (Click on Link) [Engineering Design Document](#)

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink, appearing to read "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado