



ADDENDUM NO. 1

DATE: February 24, 2026
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Pipe and Materials IFB-5866-26-KN

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Q:** Would you accept partial quote?

A: The City will not be accepting partial quotes.

2. **Q:** On the copper tubing are you looking for soft or hard tubing?

A: Copper tubing for all water service lines ¾inch through 2 inch in diameter shall be Type K , soft copper tubing for underground service conforming to ATSM B-88 and ASTM B-251.

3. **Q:** Lines 5&6: Are brass saddles with wide stainless-steel straps acceptable?

A: All tapping saddles shall be wide body, either brass or nylon/epoxy coated, wide stainless straps, CC thread.

4. **Q:** Line 7: (1" x 3/4" Tap Saddle) What information can you provide on application / type / configuration?

A: The City is deleting this line item.

Contractor shall use the revised Addendum One price quote schedule below when submitting their bids.

5. **Q:** We noticed on the bid tab that most of the MJ Fittings items accessories were specified, but line 4 and line 22 did not specify. Are accessories needed for ALL MJ Fittings?

A: All MJ fittings need full accessories packs.

6. **Q:** What are the specifications on the 4" Airvac Flanged?

A: The City is deleting this line item.

Contractor shall use the revised Addendum One price quote schedule below when submitting their bids.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink that reads "K Nelson". The signature is written in a cursive, flowing style.

Kassy Nelson, Buyer
City of Grand Junction, Colorado

Addendum One Price Bid Schedule IFB-5866-26-KN “Pipe and Materials”

Item No.	Description	Finish Type	Estimated Qty	Unit	Unit Price	Extended Price	Lead Time
1	8x 6 mj x mj reducer w/access.		1	EA			
2	4 x 6 mj x mj reducer w/access.		1	EA			
3	6 x 10 mj x mj reducer w/access.		1	EA			
4	6 x 6 x 6 tee mj		7	EA			
5	6in x 3/4in tap saddle	ductile iron body for C-900 PVC	60	EA			
6	6in x 1in tap saddles	ductile iron body for C-900 PVC	1	EA			
7	3/4 corp stops CC threads	CC threads x Compression outlets	62	EA			
8	1in corp stops CC threads	CC threads x Compression outlets	1	EA			
9	6in x 6in swivel tee for Fire Hydrant w/access.		5	EA			
10	6in x 6in mj x mj hydrant gate valves w/ access.		5	EA			
11	Fire hydrant city spec 4 1/2 ft		5	EA			
12	6in x 6in mj x mj inline valves w/ access.		6	EA			
13	6in Hymax/Romax coupling		7	EA			
14	6in mj x mj 45 degree bends w/ access.		9	EA			
15	3/4 Type k copper tubing		1390	FT			
16	1" Type K copper tubing		130	FT			
17	3/4 - 3 piece brass compression coupling: copper to copper		60	EA			
18	6in C900 DR18 CL235 Pipe		3120	FT			
19	Tracer wire		3120	FT			
20	Valve boxes		6	EA			

21	24" x 20" reducer - MJ		1	EA			
Total Extended Price:							

Total Extended Price Written:

By signing below, the Undersigned agree to comply with all terms and conditions contained herein.

Company: _____

Authorized Signature: _____

Title: _____