

ADDENDUM NO. 4

DATE: July 22, 2026
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Compressed Natural Gas (CNG) Compressor Replacement RFP-5944-26-DD

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Question:** What is the desired SCFM outlet of the compressor?

Answer: Revised Response We are requesting a 300-350 SCFM output at a 25 PSI inlet pressure.

The answer to this question was incorrectly answered in Addendum 3. Please use the above response.

The original solicitation for the project noted above is clarified as noted. All other conditions of the subject remain the same.

Respectfully,



Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado