



Purchasing Division

ADDENDUM NO. 1

DATE: February 6, 2015
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: IFB-3987-15-DH Mesa Community Center Exterior Improvements and Repairs

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. What about lead base paint remediation?
 - A. Contractor shall follow local, state and EPA rules for lead paint and disposal.
2. Chinking color shall match stain color.
3. Q. Do we seal all cracks, or just in between the planks?
 - A. Seal all crack and stain all chinking and wood to match.
4. Front door shall be refinished to factory color.
5. See attached site visit sign-in sheet.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

Name, Title
City of Grand Junction, Colorado

Solicitation Name:	Mesa Community Center Exterior Improvements and Repairs
Solicitation #:	IFB-3987-15-DH
Date:	1/30/2015
Time:	10:00am

SIGN-IN SHEET



	Company Name	Representative Name	Phone	Email
1	Hudspeth + Assoc.	Robbie Sandidge	970-319-2508	rsandidge@hudspethbiz.net
2	Westwind Painting	Mike Skillo	970-250-4324	Mike@WestwindPainting.com
3	Collbran Supply	Vin STURM	970-487-3341	
4	Sage Creek Dev	Keith Watson	970 361 8456	wcontractin53@yahoo.com
5	Andrew Pisch			
6	Pro Construction	NODY Rosal	970-242-3548	PRO NODY@ProConstruction.Crew
7				
8				
9				
10				
11				
12				
13				
14				