

BOARD OF ADJUSTMENT
MEETING

Tuesday - April 14, 1959
4:00 PM

Present: Chairman Ray Hume, Glen Hopper, and
Secretary R. E. Cheever.

Absent: Norman Hotchkiss and Claud Smith.

This meeting was called in order that the Board might consider the request of the Farm Bureau (represented by Mr. Bailey of the Independent Lumber Company) for a variance from Section 504, Table 5-A of the Building Code to permit unprotected openings on both sides of building, one side less than 5 ft. and the other side less than 20 ft. from adjacent property.

After discussion, motion was made by R. E. Cheever that the Board grant one foot variance on south side of building, with wire glass used in windows. Seconded by Mr. Hopper. Carried.

Motion was then made by Glen Hopper that variance be granted that clear (regular) glass may be used on north side of building if an entry is entered into property deed that if at any time a building is erected on adjoining lots to the north, wire glass be inserted in all north windows. Seconded by Mr. Cheever, and carried.

R. E. Cheever, Secretary