



Purchasing Division

ADDENDUM NO. 1

DATE: March 16, 2015

FROM: City of Grand Junction Purchasing Division

TO: All Offerors

RE: IFB-4020-15-DH Mesa County Asphalt Crack Fill, Seal Coat & Stripe Project

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. The following sections shall be <u>removed</u> from the solicitation documents and <u>shall not apply</u> to this project as follows:

Section 2.21 Bid Bond

Section 2.22 Performance & Payment Bonds

Section 2.23 Retention

- Under Section 3.3 Scope of Work, the Section titled Crackfill Material Specifications shall be disregarded and shall not apply to this project. Contractor shall submit pricing and <u>their</u> proposed crack fill material product specifications with their bid submittal, for review and approval by the Owner.
- 3. Q. How would you like to do the weed control in the cracks prior to the crack seal? Weeds with live roots have the potential (if not killed completely) to break the surface of the asphalt and crack filling material and cause damage. In the long run, it pays off to kill the weeds with chemicals all the way down to the roots, 2 weeks minimum prior to starting the job.
 - A. Mesa County staff will perform chemical control on all weeds in cracks over the next couple weeks prior to contractors performing work.
- 4. Q. There are two types of asphalt sealer, coal tar base and Asphalt emulsion base. Most of us use coal tar sealer because the life of the sealer is doubled as opposed to the Asphalt emulsion base sealer. I was wondering if you had a preference of which material to use.
 - A. Mesa County will allow use of a coal tar sealer on lots. All products shall be review and approved by owner prior to award.

- 5. Q. If a Contractor is awarded multiple lots, would that Contractor be allowed to perform work on said lots simultaneously?
 - A. Yes. Contractor shall coordinate with Owner.
- 6. Q. I wanted to ask about the transition cracks (asphalt to concrete). Are we going to include these in the bids or not?
 - A. No.
- 7. See attached Pre-Bid Meeting Sign In Sheet.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

Duane Hoff Jr., Senior Buyer City of Grand Junction, Colorado

	Solicitation Name:	Mesa County Asphalt Crack Fill, Seal Coat & Stripe Project 2015		
	Solicitation #:	IFB-4020-15-DH		
	Date:	3/11/2015		
Į	Time:	10:00am		

SIGN-IN SHEET





	Company Name	Representative Name	Phone	Email
1	SEALCO	BRIAN JAMES	970-275-6302	jima sealcoincorporated.com
2	AM-PM	Preston MEAchen	970-249-1273	AMPM SWEEPER @ Yalto CEM
3	Bonneville Asphalt	Russell Johns	801-471-1341	bonneville acoust (a) amail. com
4	APMORPROSEAL	MIKE HOLANIN	970 -249300	
5	BEROLAGICA			
6	PAH Egyupment	MARK DEVENCENTY	720 271 2432	MARKO @ Pheyupmentines
7	Straight 6 de Stwang LLC	Justin Franklin		Straightedos striping lle commil com
8	Art Morford	Alpine Pavement	242-8487	Trever & Alpha & GJ. com.
9	Sam Kear	Grimer Corp	970-366-65-19	San Kear lagmin corp. wan
10	G&G PAVING	THOMAS O'DELL	970 - 243 -8307	GGPAVINGTLO & YAHOO, COM
11				.5.
12				
13				
14				