



Purchasing Division

ADDENDUM NO. 1

DATE: April 20, 2015 FROM: City of Grand Junction Purchasing Division TO: All Offerors RE: IFB-4039-15-DH Replacement of Sliding Glass Doors for Orchard Mesa Pool Facility

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:


- 1. At least one door must meet ADA requirements for accessibility.
- 2. Contractor shall level out the track areas where needed.
- 3. Contractor shall not need to replace the load bearing beams, only the coverings and wood on each.
- 4. Contractor is responsible for sectioning off the work area with security fencing.
- 5. See attached floor plans for project area.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

Duane Hoff Jr., Senior Buyer City of Grand Junction, Colorado



| ROOMS 104,105,106,107 | ,108,109,11 | 0,111,112 | ,113,114,1 | 15,116 AND 117 |
|-----------------------|-------------|-----------|------------|----------------|
| DEPRESS SLAB 1/2" FOR | | | | |

NOTE:

2. ALL NON-BEARING MASONRY WALLS RUNNING PARALLEL TO JOIST, TO EXTEND 4" ABOVE FINISHED CEILING. WALLS RUNNING PERPENDICULAR TO JOIST, TO EXTEND 1/2" ABOVE FINISHED CEILING.

NEW ADDRESS WARDEN AND AND ADDRESS AND ADDRESS AND ADDRESS ADDRESS ADDRESS ADDRESS ADDRESS ADDRESS ADDRESS ADDR

. S. #.

METAL THRESHOLD

CHLORINE CYLINDERS (NIC)

-MONORAIL (N.I.C.)

NOTE: SEE POOL PLANS FOR ALL POOL AND EQUIPMENT DIMENSIONS AND LOCATIONS.

| | | | Revised 2-82-83 | |
|--|--|-------------------------|-----------------|--|
| THIS DRAWING IS THE PROPERTY OF ARIX, AND IS NOT TO BE REPRODUCED, MODIFIED OR USED FOR ANY OTHER PROJECT OR EXTENSION OF THIS PRO- JECT EXCEPT BY AGREEMENT WITH SAID COMPANY. | SCALE 1/8'' = 1'-0'' CITY OF GRAND JUNCTION MESA COUNTY | | | |
| | DRAWN <u>LC</u> CHECKED <u>FAP</u> | ORCHARD MESA POOL | | |
| | APPROVED <u>FAP</u> | GRAND JUNCTION, COLORAD | 0 | |
| | DATE <u>JULY 1982</u> PROJECT NO <u>82139.00</u> | FLOOR PLAN | 2 | |

The second