



Purchasing Division

ADDENDUM NO. 2

DATE: April 27, 2015
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: IFB-4044-15-DH Electrical Work for HVAC Roof Top Units (RTU) for Elections
Office of Mesa County Central Services Building

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Reference Drawing E2-1. One line diagram shows panel MP-1 to have a AIC rating of 18KAIC, the panel schedule shows a rating of 10KAIC. One line diagram shows 100a 3 pole breaker for transformer feed, panel schedule shows 90a 3 pole feed. One line diagram shows panel PP-8 with 22 KAIC rating, Panel schedule shows 10 KAIC rating. What is correct on these items? Also do you have a preference on manufacture of equipment and color of devices and power pole to be installed?

A. Use the one line grandam. MP-1 18KAIC, PP-8 22KAIC.

2. **The "Response Due" date & time for this solicitation shall be extended to April 30, 2015 prior to 2:30pm.**

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", is written over a horizontal line.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado