



City of Grand Junction, Colorado 81501

250 North Fifth St., 303 243-2633

February 5, 1980

Mr. David M. Leonard, P.E.  
Armstrong Engineers and Associates, Inc.  
861 Rood Avenue  
Grand Junction, CO 81501

Dear Dave:

Re: Mesa County Road Improvement District 1980

In response to your letter of January 30, 1980, the following are potential impacts on the City:

1. The sewer taps still need to be installed from the sanitary sewer to the property lines on Chestnut Drive prior to construction of the road improvements. This work could be included to be performed by the road contractor or we could do the work on time and materials basis. In any case you should determine the tap locations desired and arrange for the work as early as possible.
2. Sanitary sewer manholes on all four (4) roads should be adjusted to finished grade by the road contractor.

Thank you for the opportunity to input into the County improvement district process.

Very truly yours,

Ronald P. Rish, P.E.  
City Engineer

RPR/hm

cc - Jim Patterson  
Ralph Sterry  
Wayne Warren