

October 24, 1974

City of Grand Junction
P. O. Box 968
Grand Junction, Colorado 81501

Attn: Mr. James Patterson

Gentlemen:

This is to inform you that your "Application for Approval of Location" for a sewage treatment addition to the existing 7.3 M.G.D. Wastewater Treatment Facility to be located in the northwest one-quarter, Section 15, Township 1 South, Range 1 West, Ute Meridian, Mesa County, Colorado was approved by the Colorado Water Quality Control Commission at its regular meeting on October 15, 1974, subject to the following conditions:

1. A certification from the engineer must be furnished prior to commencement of operation, stating that the facilities were constructed as shown on the plans submitted, or a justification by the engineer and/or the operating entity of any changes that were made.
2. The facility must be operated by a certified operator in accordance with regulations established by the Certification Board for Water & Wastewater Treatment Plant Operators.
3. The facility must be connected to regional facilities and interceptors at such time as they are available, in accordance with the Basin Water Quality Plan. The works themselves, may or may not be abandoned, but the facility must be connected to the regional system.
4. This approval is rescinded on October 15, 1975 unless definite steps toward actual construction have been taken by that date. Such steps may include letting of contracts, condemnation proceedings, actual construction, etc.

This approval does not relieve the owner from compliance with all county regulations prior to construction, nor from responsibility for proper engineering, construction, and operation of the facilities.

City of Grand Junction
October 24, 1974
Page 2

Please ^{return} ~~return~~ this letter for your permanent records.

Very truly yours,

E. B. Pugsley

E. B. Pugsley, P.E., Technical Secretary
Water Quality Control Commission

EBP/GTM:dec

cc: Director, Mesa County Health Department

✓ District Engineer