

June 18, 1976

Mr. William Buttolph
2856 1/2 Bunting
Grand Junction, Colorado 81501

Re: Application for Site Approval of New Sewage
Treatment Works for Valle Vista Subdivision
Mesa County

Dear Mr. Buttolph:

This is to inform you that your "Application for Site Approval of New Sewage Treatment Works" for a 21,000 gpd non-discharging aerated lagoon to be located in the SE 1/4 of the NW 1/4 of the SW 1/4 of Section 34 TSP 1 S R 1 E, Ute Meridian, Mesa County, Colorado was approved by the Colorado Water Quality Control Commission at its meeting held on June 1, 1976 subject to the following conditions:

1. A certification from the engineer must be furnished prior to commencement of operation stating that the facilities were constructed as shown on the plans submitted or a justification by the engineer and/or operating entity of any changes that were made.
2. This facility must be operated by a certified operator in accordance with regulations established by the Certification Board for Water and Wastewater Treatment Plant Operators.
3. The facility must be connected to a regional facility and interceptors at such time as they are available in accordance with the Basin Water Quality Plan. Suitable covenants must be inserted in each property purchaser's title to insure abandonment of interim treatment facilities. This approval is rescinded ninety days from this date if suitable arrangements have not been completed.
4. This approval is rescinded on June 1, 1977 unless definite steps toward actual construction have been taken by that date.

JS

Mr. William Buttolph
Valle Vista Subdivision
June 18, 1976
Page 2

We have not received completed plans and specifications for the wastewater collection system and treatment facility for our review and comments. State law requires that we review plans and specifications prior to construction of the system.

This approval does not relieve the owner from compliance with all county regulations prior to construction nor from responsibility for proper engineering, construction, and operation of the facility.

Please retain this letter for your permanent records.

Very truly yours,

Evan D. Dildine
Technical Secretary
Water Quality Control Commission

EDD:dec

cc: Mesa County Health Department
Robert P. Gerlofs
District Engineer