



COLORADO DEPARTMENT OF HEALTH

4210 E. 11TH AVENUE

DENVER 80220

PHONE 388-6111

ANTHONY ROBBINS, M.D., M.P.A. EXECUTIVE DIRECTOR

December 2, 1976

Mr. James Patterson
Utilities Director
City of Grand Junction
250 North 5th Street
Grand Junction, Colorado 81501

Re: NPDES Permit Number CO-0026417, Non-Compliance July and August 1976

Dear Mr. Patterson:

Self-monitoring data submitted for the period of July 1976 indicated non-compliance for the following parameters:

<u>Month</u>	<u>Parameter</u>	<u>Permit Limits</u>	<u>Self-Monitoring Data Maximum Reported Level</u>
	Total Chlorine Residual	0.5 mg/l	1.2 mg/l
July			1.1 mg/l
Aug			

Please advise this Division within 30 days of receipt of this letter the reasons for non-compliance and the necessary action taken to prevent future violations.

Very truly yours,

FOR DIRECTOR, WATER QUALITY CONTROL DIVISION

Paul E. Williamson

Paul E. Williamson, P.E. Acting Chief
Monitoring & Enforcement Section

cc: Marshall Fisher, EPA

PW/jd