



Ralpa

City of Grand Junction, Colorado

114

March 23, 1983

Central Grand Valley Sanitation Dist.
589 Grand Valley Drive
Grand Junction, CO 81504

Attention: Fred Bishop.

Dear Mr. Bishop,

Attached is a list of necessary maintenance items to be performed before we can continue with the collection system line cleaning.

Will you call me as soon as this work has been completed so we can continue with this work? 244-1577

Respectfully,

Jerry O'Brien-Facility Supervisor
Wastewater Treatment

cc: Ralph Sterry
Edith Kinder

CITY OF GRAND JUNCTION
COLLECTION SYSTEMS

C.G.V.S.D. NEEDED REPAIR AND MAINTENANCE
MARCH 23, 1983

LOCATION	REMARKS	WORK TO BE DONE
1. 2964 Northacre Ct.(off of Broken Spoke Rd.)		Raised
2. 2964 Music Ct. (off of Broken Spoke Rd.)		Raised
3. Ft. Uncompahgre Dr. F 3/4 Rd.		Raised
4. Hudson Bay Dr. between F 1/4 & F 3/10		Raised
5. West of 30 Rd & North of F Rd. (all of these)		Raised
6. F 1/2 & 628 S. on 29 1/2 (can not get from MH between F 1/2 & 628 S. on 29 1/2 Rd. MH is under fence and burried in a field)		
7. 612 Ox Bow Rd. (cracked)		Replaced
8. 30 Rd. between F 3/4 & F 1/2 (needs fill dirt around all manholes)		
9. 30 Rd. between F Rd. & Green Pl. (located and raised-all)		
10. Between Green Pl. & 591 Ronlin St.		Raised
11. McMullin Dr. & Cline Ct. (MH bottom very rough)		
12. 599 Gerken Rd.		Asphalt Covered
13. McMullin Dr. & Bookcliff Ave		Raised
14. First MH East of McMullin Dr. on Bookcliff Ave.		Raised
15. On Walnut Ave. between Grand Valley Dr. & Bookcliff		Raised
16. MH East of Grand Valley Dr. on Walnut Ave.		Raised