



Purchasing Division

ADDENDUM NO. 1

DATE: August 14, 2015
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Potable Water Storage Tank(s) IFB-4087-15-NJ

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- Question 1:** "I want to double check the NSF approval requirement listed. We have access to NSF approved material for construction of these tanks but our company itself does not have NSF Certification. Will you still accept our bid if the tank is not stamped with the NSF Mark but proven to be manufactured with NSF approved materials?"
Response: The tank manufacturer must show that they hold the proper NSF Certification.
- Question 2:** "Are any of the external parts and pieces shown on attachment A included in the price request? If so, are there any specifications for those items? If so, there are no "NSF flexible connectors" shown on the tank flanges which is a requirement for fiberglass tanks."
Response: Please refer to "Question and Response 4" of this Addendum 1.
- Question 3:** "Our quotation will include fuel at today's pricing but actual delivery charges cannot be determined until these tanks are ready to ship in 8-10 weeks. Your comments?"
Response: Contractor shall submit a set price for the tanks delivered FOB to the job site. This procurement is anticipated to require City of Grand Junction City Council approval and set pricing will be required for approval.
- Question 4:** "Could you please clarify, would like a price for just the tanks only? Or do we need to include the solid sleeves and valves and valve box's as on the drawing?"
Response: The bid price will need to include the tanks, and appurtenances to extend the vents and man way access two feet, that are located on the top of the tank (see shaded areas and arrow limits in the Attachment to this Addendum 1).
- Question 5:** "Is there a difference for NSF certified that your bid calls out for versus NSF 61 which is the NSF standard for drinking water?"
Response: No

6. **Question 6:** "Section 2.5, "Warranty." Can you please state how long of a tank warranty you are looking for from the manufacturer."

Response: 20 years for materials minimum.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Nicholas C. Jones". The signature is written in a cursive style.

Nicholas C Jones, Buyer
City of Grand Junction, Colorado

