



Purchasing Division

## ADDENDUM NO. 2

**DATE:** August 14, 2015  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** IFB-4079-15-DH CLETC Water Line Project

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. The tank contractor will be furnishing the 30" riser. The contractor will pour the 6" concrete pad around the 30" riser. The meter assembly will be a lid slab with standard 24" manhole opening.
2. The Contractor may utilize a casing pipe material differing from the 12" DR-11 HDPE specified. The alternate casing pipe material shall meet CDOT specifications. The Contractor shall be responsible for obtaining CDOT approval of the alternate material prior to installation. The casing pipe must be sized to allow installation of the 6" C-900 carrier pipe without damage to the carrier pipe.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", is written over a white background.

Duane Hoff Jr., Senior Buyer  
City of Grand Junction, Colorado