



Purchasing Division

ADDENDUM NO. 1

DATE: February 1, 2016

- FROM: City of Grand Junction Purchasing Division
- TO: All Offerors
- RE: RFP-4166-16-DH Design Services for City of Grand Junction Water Treatment Plant Filter Upgrade Project

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

Notes and clarifications from January 27, 2016 Site Visit Meeting:

- 1. The cost proposal will be submitted as a separate submittal package.
- 2. The City will make contact with the CDPHE to make them aware of the proposed project.
- 3. Current capacity of the four existing filters if 4 MGD/filter
- 4. The existing backwash pumps will remain in service.
- 5. As-constructed plans of the water Treatment Plant are accessible from the City GIS Utility map. The following link will take you to the water plant. Click on City Water in the map legend, then click on one of the water lines leaving the plant. Click on the yellow 'click here for more info', that is in the information box, and that will get you to the as-constructed drawings. <u>http://arcgis-</u>

fs.ci.grandjct.co.us/internal_gis_map/index.html?map=utilitiesmap&extent=710938,4323742,71 1224,4323883

- 6. Backwash pumps are VFD driven.
- 7. Surface water wash piping will need to be removed with this project.
- 8. Filter troughs have been modified from those shown on the as-constructed plans.
- 9. Concrete in the filter bays appears to be in good condition.
- 10. The boxes at the end of the filter bays are vents to the clear well.
- 11. This is a voluntary project on the part of the City. There is no requirement for this upgrade from CDPHE.
- 12. It is anticipated that a new power supply will need to be provided for the blowers.
- 13. The new equipment should be configures with the expectation of having SCADA upgrade in the next few years.

There is a one line drawing on sheet 30 of the original as-constructed drawings.

14. Q. Does the WTP currently utilize both backwash pumps concurrently?

- A. They do not.
- 15. Q. Would it be OK for me to call you directly to discuss the request for planning services? At the same time, I would like to find out if there are other projects planned for 2016 where we might assist the City.
 - A. We do not have a full scope of services put together on the facilities studies for the plants. We would prefer not to discuss this particular project until we have the scope tighter.
- 16. See attached Site Visit Sign In Sheet.
- 17.Q. Does the City desire to install 2 blowers (1 for redundancy)?
 - A. We would expect that two blowers would be needed for redundancy.
- 18. Fee proposal shall be submitted electronically, as per the instructions stated in Section 1.6 and 5.0 "Submission". However, the fee proposal shall be in a separate file unto itself, marked "Fee Proposal", as the fees will not be viewed until a final selection has been made.
- 19. See attached one line diagrams is for the electrical service to the plant that was upgraded in 2013.
- 20.Q. Is a new service, meter and transformer expected to be required with this project? Can the existing MCC be used?
 - A. A new electrical service may be needed to provide power for the blower(s). There is an existing 400 amp service in place.


The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.


Respectfully,

Duane Hoff Jr., Senior Buyer City of Grand Junction, Colorado

Solicitation Name:	Design Services for City of GJ Water Treat	ment Plant Filter Upgrade	SIGN-IN SHEET	
Solicitation #:	RFP-4166-16-DH			
Date:	1/27/2016	(Grand Junction	
Time:	1:00pm			
π				
Company Name	Representative Name	Phone	Email	
AVL	Adam Racette	517-282-3656	, aracette e juajua.com	
JVA	Cooper Best	970-987-0356	1 chest @jvajva. com	
ULSSON ASSOCIATES	WYATT POPP	970 263 7800	WPOPP@ OLSSONASSOCIATES. COM	
BROWNS HILLENG & Cond Nois	harles PAGE	303-335-5484		
TETRA TECH IMR	TOM SAXTON)	970-639-2555		
AEcom	Joshua Shuckelford	970-456-9334	Joshun- shackelford @ accom-com	
AECOM	David Slade	970 - 379 - 4246	david . d. slack @ accom. com	
SMA	EITC Krch	970-901-8568	evic, kuch e souder miller. 10m	
56M	Ryan Loebach	970-284-9069	ryanle sgm-inc.com	
	J		, ,	
n 				




		12" CONC WALL
		ORADO / C
		133294 S
		WAL ENGINEE
	12-089	
7.1	DATE DRAWN:	ORCHARD MESA WATER TREATMENT PLANT
nc.	10-02-12	
	10-02-12 Drawn by:	ELECTRICAL RELOCATION PROJECT CITY OF GRAND JUNCTION, COLORADO



SERVICE DIMENSIONS

SECTIONS ARE TO BE REARRANGED AS SHOWN IN THE ELEVATION DRAWING.





ENGLISH DIMENSIONS: INCHES


DRAWING NO .:	REFERENCE DRAWINGS:	

		PROVIDE 4" CONCRETE CURB U THE TWO PRODUCTION METERS AND THE TWO ARRAY DISCONNE SECTION. PROVIDE ALL LABELING THE DISCONNECTS. THE BREAKE BREAKERS WITH LOCKOUT ABILIT	ARE TO BE CTS ARE TO REQUIRED RS INSTALLE	BE MOUI	NTED ON	on the s ompany i	FOR THE PV ME
							Bighor
							Consult
							and the second second
							Engine
							Mechanical 569 S. West
	11						Grand Juncti
	1						phone: 970-2
REV:	DATE:	REVISION DESCRIPTION:	BY	BY	BY	BY	fax: 970-241

SERVICE ELEVATION	SER\	/ICE	ELE\	/AT	ION
-------------------	------	------	------	-----	-----

SERVICE ELEVATION			
NOT TO SCALE			
PROVIDE 4" CONCRETE CURB UNDER PANEL MB.	-	FOURTU	~
THE TWO PRODUCTION METERS ARE TO BE INSTALLED ON THE FRONT OF AND THE TWO ARRAY DISCONNECTS ARE TO BE MOUNTED ONTO THE SIDE	OF T	THE FOU	RT

M	400 AMP 400 AMP	150 PV ARRAY AMP 100 PV ARRAY AMP
UTILITY CO CT COMPARTMENT	400 AMP ATS SWITCH	60 AMP SPARE □ SPACE □ SPACE □ SPACE □ SPACE □ SPACE □ SPACE



	BT-200 120 VAC 10 FLA BT-200 120 VAC 0.5 FLA 0.5 FLA	MUZ OCF TIM

N:\LandProj\Justin - 2011 Clortech Unit - Water Treatment Plant\City GJ WTP BaseJJV 6-27-12.dwg, 7/12/2012 10:04:59 AM, DWG To PDF.pc3

