



Purchasing Division

ADDENDUM NO. 1

DATE: June 30, 2016
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: IFB-4258-16-DH Sallyport Four-Fold Door Replacement Project for Mesa County Detention Facility

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Is certified payroll required? Prevailing wage?
A. No.
2. Q. Are background checks required?
A. Yes. They must be processed through the Mesa County Sheriff's Department.
3. Existing safety loops and detectors will be reused and connected as safety loops to new system.
4. Signs and sign striping for the doors will be done by Owner.
5. New doors can be staged on site until installation is complete. Existing doors can be stored on site and removal is by Mesa County personnel. Necessary equipment can be stored on site during installation.
6. Building must have one door completely operable at all times.
Second opening must be secured at end of each day before leaving site.
Materials used to secure the building are responsibility of contractor.
7. Bid bond will be scanned and attached to bid response when electronically submitted.
8. Tool inspection will be performed on a daily basis for all contractor employees and subcontractors.

9. Doors will be provided with 2 sets of safety photo eyes. Where will they be located? Normally one set would be outside the opening and second set inside the opening. Doors will be provided with pneumatic sensing safety edges. Safety devices are required to meet UL 325 regulations.

10. Main incoming power supply is 460 volt and will be reconnected. Existing electrical EMT and flex can be reused where possible. All wiring is the responsibility of the contractor.

11. Existing steel jambs will be reused in current condition.

12. Doors will come cleaned and prime painted. Installation work that needs painted will be cleaned, prepared, and prime painted using matching primer. Final paint coat is not included in product being supplied by EPD.

13.Q. Is there a specific bid bond form? We were unable to locate a form.

A. There is no specific bond form. You may utilize the form from your surety/insurance company.

14.Q. On the bond form do we fill in for the owner; Mesa Co. or City of Grand Junction?

A. The Owner of this project is Mesa County. Use Mesa County for the bond form.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", is written over a yellow horizontal line.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado