



Purchasing Division

ADDENDUM NO. 1

DATE: September 12, 2016
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Pedestrian Lighting Installation for North Avenue (12th Street to 23rd Street)
IFB-4286-16-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Ground rods at each pull box, shall be installed or already are installed?
 - A. Ground rods shall be install in each pull box as part of this project.
2. Q. Pea Gravel is included in pull box pay item? Sheet 12 of bid package.
 - A. Pea gravel shall be installed in each pull box as part of this project.
3. Q. In-Line Fuse holder installed in pull box or at hand hole? Sheet 12 of bid package.
 - A. In-Line fuse holder should be installed in hand holes.
4. Q. Are the light pole assembled with the heads?
 - A. No. the poles, arm assemblies and heads are not assembled.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado