



Purchasing Division

ADDENDUM NO. 3

DATE: November 3, 2016
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 2016 Sewer Interceptor Repair and Replacements IFB-4297-16-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Would the City accept Manhole SprayGlass rehabilitation as and approved alternate to the current specifications?

A. The Manhole SprayGlass rehabilitation submittals have been reviewed and approved.
2. Q. GJ references use of Persigo drying beds for clean & cctv debris. Will sub then need to haul off and pay disposal fees once dry? Or will GJ be accepting and taking care of the debris?

A. Correct.
3. Q. Page 53 references install as pull in ASTM F1743 but later mentions that the install be inversion. In this diameter, it should be inversion only or a choice as ASTM F1743 AND ASTM F1216. Please clarify.

A. This is Contractor's choice.
4. Q. Page 54 references AISC only; page 49 references curing resin using water. Can the owner clarify if both methods are allowed?

A. Both shall be allowed.
5. Q. On the abandonment of MH's, is that to take place before or after CIPP Installation? As it sits right now per detail MH-3, the cross braces will either interfere with the lining (if they want it done before) or not be able to be placed (if after lining).

A. Abandonment of manholes shall take place following CIPP installation.
6. Q. Being that we are installing cleanouts on top of live service connections, do we need to anticipate bypassing each service 24/7 during the CIPP install?

- A. Correct. Note that these cleanouts are located at services to businesses. The contractor will be responsible for bypass during business hours. 24/7 bypass may not be necessary.
7. Q. Do inverts of the MH's need to be rehabbed that will require bypass? Don't see anything in the spec but just want to make sure, this will impact our bypass days.
- A. No, the manholes are to be rehabbed from spring line up.
8. Q. Can we elect to trench "G" Road instead of installing the (2) 18" Casing?
- A. Yes
9. Q. On page 49 of the Specifications, 3.1.1, the last sentence: "In addition, at least 50,000 linear feet of the product shall have been in successful service within the State for a minimum of five years." We have seen this in other projects and have requested that the "State" requirement be removed. With millions of feet of CIPP installed across the US, and previously with other companies, we do not feel the sewers in Colorado are different in any way that would dictate that this requirement is necessary. WE do not have the footage, especially at the diameter similar to this scope, installed in the state, however I believe you will see that our CIPP products meet or exceed all other requirements and our personnel has the expertise necessary to complete this project to your expectations.

On page 50 of Specifications, 3.1.3, the first sentence: "Both the rehabilitation manufacturing and installation processes shall operate under a quality management system which is third-party certified to ISO 9000..." This is another requirement that we see often and request it be removed. Our CIPP Manufacturer is ISO certified and we can provide Proof of the Certification. We technically do not ISO certify the installation process, in fact I believe only one company did certify the installation process, when there was only one company in the industry. It is not necessary to certify the installation process when the Manufacturer trains and certifies the installer to install the CIPP product under the quality management process required to be a certified installer of the product.

- A. Pertaining to this question, for this project, the criteria as set forth in the solicitation documents shall remain.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,



Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado