



Purchasing Division

## ADDENDUM NO. 3

**DATE:** June 26, 2017  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Riverside Parkway Access Improvements IFB-4387-17-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Storm Drain Installation** – To clarify City of Grand Junction Crews are to install approximately 40 linear feet of 12” storm drain pipe (RCP) and tie into existing manhole per Plan Sheet 15 prior to construction commencing. The Contractor shall install remaining pipe required and vertical curb inlet. Bid Schedule (Addendum No. 2) reflects these changes.
2. **Bid Schedule** - Line Item No. 1 Units shall be paid for by Lineal feet and Line Item No. 9 in square yards.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white rectangular background.

Duane Hoff Jr., Senior Buyer  
City of Grand Junction, Colorado