



Purchasing Division

ADDENDUM NO. 2

DATE: July 18, 2017
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 28 ½ Road Sewer and Water Line Replacement and Overlay IFB-4399-17-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Item #2- 6" DR18. Does this pipe include the piping for the fire hydrants?
A. Correct.
2. Q. Item #17- 4" Sewer service taps. I count 29 on the plans and profile...schedule says 30.
A. There are 29 Sewer Service Taps identified per the Plan Set. In lieu of supplying a revised bid schedule, the most current Bid Schedule (Addendum No. 1) shall be used for bidding the project.
3. Q. Item #10(only qty 1 tee, 6" line connection) and #11- Assuming the tees are FlgxFlg, should we add the MJxFLG adapters in this item? Or are you going to add another line item? Or should MJxFLG tees be quoted where possible?
A. MJxFLG Tee's to be quoted where possible.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado