



Purchasing Division

ADDENDUM NO. 4

DATE: July 24, 2017
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: Persigo Wastewater Treatment Plant Diffuser Outfall Improvements Project
IFB-4396-17-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. On Sheet 14 of 17, Detail 2 Casing Pipe installation: States fill void with Sand, Pea Gravel or K-crete, will annular blow sand be acceptable for filling the annular space between casing and carrier thru the bore?
 - A. Yes, annular blow sand will be acceptable, as well as, fly ash slurry.
2. Q. Per Addendum #2, CDOT's Joel Berschauer's email states that the bore can be shortened by up to 50-ft with the remaining pipe to be open trenched, will a new bid schedule be provided shorting the 420 LF quantity of trenchless installation to 370 LF? What is the exact quantity of the trenchless steel casing that is to be installed by trenchless method?
 - A. A new bid schedule will not be issued. Regardless on whether the Contractor bores all 420 LF or if the Contractor bores 370 LF and open trenches 50 LF, there will still be a total of 420 LF of steel casing pipe installed from right-of-way line to right-of-way line installed. The Contractor has the option of shortening up the bore per Joel's email, but is not required to.
3. Q. Is the use of Permalok steel acceptable for the tunnel? We would like to install the tunnel with Permalok and weld the casing from the inside after the tunnel is completed. Please advise if this is an acceptable alternative.
 - A. Yes, Permalok is an acceptable material for the steel casing. However, so we're clear, Permalok is not acceptable as the final conveyance pipe underneath I-70. That is, a carrier pipe (HDPE) would still be required within the Permalok pipe.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written in a cursive style.

Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado