

Purchasing Division

ADDENDUM NO. 2

DATE: August 7, 2017

FROM: City of Grand Junction Purchasing Division

TO: All Offerors

RE: Concrete Slab Construction for Streets Salt Shed IFB-4402-17-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. No concrete joints to the internal to the slab will be required for this project. The reinforcing mat is designed to control the width of random cracking without the use of control joints.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

Duane Hoff Jr., Senior Buyer City of Grand Junction, Colorado