



Purchasing Division

ADDENDUM NO. 1

DATE: March 13, 2018
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 2018 Contract Street Maintenance – Asphalt Overlays IFB-4489-18-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. Will the City provide survey, or will the survey be incidental to the shoulder widening on River Road?
 - A. Any survey deemed necessary by the contractor will be considered incidental to the shoulder widening on River Road. The City will not provide survey services for this project. However, the City may survey final grades of the shoulder widening to verify that minimum slopes of the embankment have been met.
2. Q. What is the depth of base course beneath the shoulder widening section on River Road?
 - A. 12 inches of Class 6 Aggregate Base Course will be placed beneath the new asphalt shoulders as indicated on the attached standard detail.
3. Q. Can cut/fill information for River Road be provided?
 - A. See the attached fill section sheets. At least some cut should be assumed for the remaining areas within the project boundaries. However, these identified fill sections are by no means entirely inclusive, and some localized areas of fill should be anticipated elsewhere throughout the shoulder widening.
4. Q. Will the bid be awarded on the base bid, or the included bid alternates?
 - A. Should the City decide to include one or both alternates in this project, said alternates will be added to the base bid price to determine an awarded bidder. Contractor shall utilize the attached updated Addendum 1 Price Bid Schedule in submitting their bid response.
5. Q. Will night work be allowed elsewhere besides River Road and what would those working times be?

- A. Night work may be allowed elsewhere, where approved by the City, on a case-by-case basis. Working hours for these approved locations from 7PM to 7AM will generally be acceptable, although these times should be approved/confirmed by the City prior to construction.
6. Q. Bid Item 2 "Excavation & Embankment" has a bid quantity of 2,010 CY & refers us to SP-2. The notes in SP-2 state that "The Engineer estimates the materials cut from the east sections of River Road will generate approximately 3,970 cubic yards of material."
- A. We anticipate that the cut materials will generate 3,970 CY. We anticipate approximately 2,010 CY will be placed at the west end of River Road as embankment. The contractor will be paid for the planned 2,010 CY of materials completed in place. The contractor then takes ownership of the remaining materials per our excess materials clause (3.3.22).

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,



Duane Hoff Jr., Senior Buyer
City of Grand Junction, Colorado

Bid Schedule: Addendum 1 - 2018 Contract Street Maintenance - Overlays and Improvements

Contractor: _____

Item No.	CDOT, City Ref.	Description	Quantity	Units	Unit Price	Total Price
1	202	Asphalt Removal (Planing)(Thickness Varies - Maximum 3")	78,861.	SY	\$ _____	\$ _____
2	203	Excavation and Embankment (New Bike Lanes - See SP-2)	2,010.	CY	\$ _____	\$ _____
3	210	Adjust Valve Box (Price to Include adjustment of Survey Monuments)	131.	EA	\$ _____	\$ _____
4	210	Adjust Manhole Ring and Cover (Sanitary and Storm Sewer)	112.	EA	\$ _____	\$ _____
5	210	Reset Mailbox Structures	3.	EA	\$ _____	\$ _____
6	304	Aggregate Base Course (Class 6) - Shoulder Edging Gravel	3,427.	Tons	\$ _____	\$ _____
7	304	Aggregate Base Course (Class 6) - Bike Lane	8,824.	Tons	\$ _____	\$ _____
8	401	Hot Mix Asphalt (1" thick Pre-level) (Grading SX, Binder Grade 64-22)	3,068.	Tons	\$ _____	\$ _____
9	401	Hot Mix Asphalt (2" thick) (Grading SX, Binder Grade 64-22)	6,131.	Tons	\$ _____	\$ _____
10	401	Hot Mix Asphalt (3" thick) (Grading SX, Binder Grade 64-22)	560.	Tons	\$ _____	\$ _____
11	401	Hot Mix Asphalt (1.5" thick) (Grading SX, Binder Grade 76-28)	4,512.	Tons	\$ _____	\$ _____
12	401	Hot Mix Asphalt (2" thick) (Grading SX, Binder Grade 76-28)	3,460.	Tons	\$ _____	\$ _____
13	401	Hot Mix Asphalt (2" thick) (Grading SX, Binder Grade 64-22) - Bottom Lift Bike Lane	1,515.	Tons	\$ _____	\$ _____
14	412/602/304	Portland Concrete Cement Concrete Pavement (8" thick) (Class E) - Include 6" CDOT Class 6 Aggregate Base Course and Reinforcing Steel	312.	SY	\$ _____	\$ _____
15	608/304	Concrete Drainage Pan (3' Wide) To Include 6" of Class 6 Aggregate Base Course	500.	LF	\$ _____	\$ _____
16	608/304	Concrete Curb and Gutter (2.5' Wide) To Include 6" of Class 6 Aggregate Base Course	401.	LF	\$ _____	\$ _____
17	608/304	Concrete Curb and Gutter (2' Wide) To Include 6" of Class 6 Aggregate Base Course	1,360.	LF	\$ _____	\$ _____
18	608/304	Concrete Sidewalk (4" Thick) to Include 6" of Class 6 Aggregate Base Course	6.	SY	\$ _____	\$ _____
19	608/304	Concrete Drive way Section (8"Thick) to Include 6" of Class 6 Aggregate Base Course	32.	SY	\$ _____	\$ _____
20	620	Sanitary Facility		Lump Sum	---	\$ _____
21	626	Mobilization		Lump Sum	---	\$ _____

Bid Schedule: Addendum 1 - 2018 Contract Street Maintenance - Overlays and Improvements

Contractor: _____

Item No.	CDOT, City Ref.	Description	Quantity	Units	Unit Price	Total Price
22	627-00002	Preformed Thermoplastic Pavement Marking	210.	SF	\$ _____	\$ _____
23	627-30405	Preformed Thermoplastic Pavement Marking (Word/Symbol)	1,690.5	SF	\$ _____	\$ _____
24	627-30410	Preformed Plastic Pavement Marking (X-Walk/Stopline)	1,918.	SF	\$ _____	\$ _____
25	630	Traffic Control (Complete In Place)		Lump Sum	---	\$ _____
26	630	Flagging	4,260.	HR	\$ _____	\$ _____
27	630	Traffic Control Plan		Lump Sum	---	\$ _____
INC		Incentive HMA 64-22 (Except Pre-Level)	---	---	---	\$ 30,000.00
INC		Incentive HMA 76-28 (Except Pre-Level)	---	---	---	\$ 30,000.00
MCR		Minor Contract Revisions	---	---	---	\$ 150,000.00

Bid Amount: \$ _____

Bid Amount: _____ **dollars**

BA1	BID ALT 1	Hot Mix Asphalt (Grading SX, Binder Grade 64-22) (with Fiber)	2,998.	Tons	\$ _____	\$ _____
BA2	BID ALT 2	Hot Mix Asphalt (Grading SX, Binder Grade 76-28) (with Fiber)	1,820.	Tons	\$ _____	\$ _____

Alternate Bid Amount: \$ _____

Alternate Bid Amount (Includes BA1 and BA2): _____ **dollars**



REVISION	DESCRIPTION	DATE	DRAWN BY	DATE
REVISION <input type="checkbox"/>				
REVISION <input type="checkbox"/>				
REVISION <input type="checkbox"/>				
REVISION <input type="checkbox"/>				

DATE	DESIGNED BY	DATE	CHECKED BY	DATE	APPROVED BY

SCALE
1" = 100'
0 25 50 100

Grand Junction
COLORADO

PUBLIC WORKS
ENGINEERING DIVISION

2018 RIVER ROAD
NORTH FILL SECTION



0+00 1+00 2+00 3+00 4+00 5+00 6+00 7+00 8+00 9+00


2945-053-13-002
 2331 RIVER RD
 GRAND JUNCTION, CO 81505
 POWER LAND COMPANY II LLC
 PO BOX 28
 DENVER, CO 80201-0028

2945-053-00-111
 2345 RIVER RD
 GRAND JUNCTION, CO 81505
 A & G PARTNERSHIP LLP
 710 S 15TH ST
 GRAND JUNCTION, CO 81501-4612

2945-053-00-111
 2345 RIVER RD
 GRAND JUNCTION, CO 81505
 A & G PARTNERSHIP LLP
 710 S 15TH ST
 GRAND JUNCTION, CO 81501-4612


REVISION	DESCRIPTION	DATE	DRAWN BY	DATE
REVISION <input type="checkbox"/>				
REVISION <input type="checkbox"/>				
REVISION <input type="checkbox"/>				
REVISION <input type="checkbox"/>				

DESIGNED BY	DATE
DESIGNED BY	DATE
CHECKED BY	DATE
APPROVED BY	DATE



PUBLIC WORKS
 ENGINEERING DIVISION

2018 RIVER ROAD
 SOUTH FILL SECTION



DRAWN BY: HMC
 DATE: 2018
 SCALE: 1" = 5'
 APPR. BY: ECM
 FILE NO. River Rd Overlays.dwg



PUBLIC WORKS
 ENGINEERING DIVISION
 2018 RIVER ROAD
 STANDARD DETAIL