FEE\$ 10.0	0
TCP\$	
SIE \$ 292,00	

PLANNING CLEARANCE

BLDG PERMIT NO. 79954

(Single Family Residential and Accessory Structures)


Community Development Department



Your Bridge to a Better Community

BLDG ADDRESS 661 CARCETT WAY	SQ. FT. OF PROPOSED BLDGS/ADDITION 1593
TAX SCHEDULE NO. 2945-037-00-166	SQ. FT. OF EXISTING BLDGS
SUBDIVISION GARACTT ESTATES	TOTAL SQ. FT. OF EXISTING & PROPOSED 1593 P
FILING	NO. OF DWELLING UNITS: Before: After: this Construction NO. OF BUILDINGS ON PARCEL Before: After: this Construction USE OF EXISTING BUILDINGS DESCRIPTION OF WORK & INTENDED USE
	all existing & proposed structure location(s), parking, setbacks to all cation & width & all easements & rights-of-way which abut the parcel.
ZONE	Parking Req'mt
structure authorized by this application cannot be occup Occupancy has been issued, if applicable, by the Buildir I hereby acknowledge that I have read this application and ordinances, laws, regulations or restrictions which apply the structure of the second se	I the information is correct; I agree to comply with any and all codes, o the project. I understand that failure to comply shall result in legal
Applicant Signature Department Approval	Date 14 MANO Date 5 1100
Additional water and/or sewer tap fee(s) are required:	YES NO W/O No.
Utility Accounting	mer Date 5-16-0/
VALID FOR SIX MONTHS FROM DATE OF ISSUANCE	(Section 9-3-2C Grand Junction Zoning & Development Code)

GARRETT ESTATES SUBDIVISION





May 23, 2001

Lee Homes Inc. P.O. Box 40521 Grand Junction, CO 81504

Attention:

Mr. Rick Brown

Subject:

Excavation Observation

661 Garrett Way

Lot 6, Garrett Estates Subdivision, Block 1

Grand Junction, Colorado

Job No. 646

As requested, a Geotechnical Engineering Group, Inc. representative visited the site and observed the open foundation excavation on May 18, 21 and 22, 2001. Soils found in the excavation appeared to be consistent with those identified by the "Geotechnical Exploration for Gerrett Estates in Grand Junction, Colorado" dated April 20, 2000, prepared by Western Colorado Testing Inc. (their Job No. 205900). We observed the completed excavation prior to fill placement and a proof roll, made by a JD500C with a full bucket of a 12-inch dapth lift of fill that revealed no significant yielding on the area observed. We believe the foundation soils are suitable to support a shallow foundation system with a maximum bearing pressure of 1,000 psf as described in the referenced report. We understand turned down slab foundations are proposed for the residence and foundation plans have been reviewed by Mesa County Building Department. In our opinion, turned down slab foundations designed and constructed to meet or exceed Mesa County Minimum House Foundation Standards and the referenced report will be suitable for the residence. This opinion is based on observation of the completed excavation and proof roll of the proposed foundation subgrade.

We appreciate the opportunity to provide geotechnical services. When we can be of further service, please call.

Sincerely,

GEOTECHNICAL ENGINEERING GROUP, INC.

John P. Withers, P.E. Principal Engineer

JPW:mk (1 copy faxed)

Geotechnical, Environmental and Materials Testing Consultants

(970) 245-4078 • fax (970) 245-7115 685 West Gunnison Ave., Suite 110, Grand Junction, Colorado 81505