



Purchasing Division

## **ADDENDUM NO. 7**

**DATE:** March 28, 2019  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** 2019 Monument Road Bicycle Path Trail IFB-4618-19-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. The response to question 2 on Addendum 6 did not clarify the scope of bid item 16. What is the location and scope of bid item 16 – Shoring (Area 1)?

A. The shoring is adjacent to the north abutment of the pedestrian bridge, due to its proximity to the existing pavement on Monument Road.

The City of Grand Junction utilizes the latest Standard Specifications for Road and Bridge Construction published by CDOT on their web page:

[https://www.codot.gov/business/designsupport/cdot-construction-specifications/2017-construction-standard-specs/2017-specs-book/standard-specifications-2017-final.pdf/at\\_download/file](https://www.codot.gov/business/designsupport/cdot-construction-specifications/2017-construction-standard-specs/2017-specs-book/standard-specifications-2017-final.pdf/at_download/file)

Section 206.09 states that, "The Contractor shall locate, size, design, and construct shoring which provides all necessary rigidity, and supports the loads imposed to facilitate construction as shown on the plans." It is recommended that the bidder become familiar with this specification on Shoring prior to bidding.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", written over a white background.

Duane Hoff Jr., Senior Buyer  
City of Grand Junction, Colorado