



**GENERAL NOTES**  
 1. TOP OF ECCENTRIC CONE TO BE SET @ TOP OF SUBGRADE (STREET CONTRACTOR TO SET RIMS TO FINISH GRADE OF STREET.)  
 2. ALL CONSTRUCTION TO BE DONE IN ACCORDANCE WITH THE CENTRAL GRAND VALLEY SANITATION DISTRICT SPECIFICATIONS.

A final inspection determined that infiltration does not exceed 200 gallons per inch diameter per mile of length per day.

Approved \_\_\_\_\_ Date: \_\_\_\_\_  
 Central Grand Valley Sanitation District