



NOTES:

The sewage collection system shall be constructed in accordance with the policies and specifications of the Central Grand Valley Sanitation District.

The water distribution system shall be constructed in accordance with the policies and specifications of the Clifton Water District.

**SEWER QUANTITIES**

6" Sewer	1831.6 L.F.
Shallow Manhole ( 6" )	10 Each
Manhole Over Existing Sewer	1 Each
8" X 4" Taps	38 Each
4" Sewer to Property Line	1070 L.F.
4" Sewer to 10' Inside Property	380 L.F.
Pavement Replacement	22 L.F.
Trench Compaction	2900 L.F.
Compaction Testing	Lump Sum
Concrete Encasement	40 L.F.



**AS-BUILT**

WESTERN ENGINEERS, INC.

CHEROKEE VILLAGE

**SEWER & WATER PLAN**

**SEWER PROFILE**

MESA COUNTY, COLORADO

ENGINEERED T.K.H. DRAWN A.S.C. CHECKED T.H.M.

GRAND JUNCTION, COLO. DWG. 430-916-4 1/18/88

INFILTRATION DOES NOT EXCEED 200 GAL / DAY / IN. DIA. / MILE.